

# RSMFM-3 | MULTIFUNCTIONAL CO<sub>2</sub> ROOM TRANSMITTER, POM

Modbus register map



## MODBUS REGISTER MAP

INPUT REGISTERS					
		Data type	Description	Raw data range	Values
1	Temperature reading	signed integer	Actual temperature level	-300–700	500 = 50,0°C
2	Temperature output value	unsigned integer	Output value according to temperature	0–1.000	1.000 = 100 %
3	Temperature alert flag	unsigned integer	Flag indicates that measured Temperature is outside set alert values. Set to '1' when the measured value is outside the Temperature alert values defined by holding registers 13 and 14	0, 1	0 = Temperature measurement OK 1 = Temperature measurement too low/high
4	Temperature range limit flag	unsigned integer	Flag indicates that measured temperature is outside set range limit values. Set to '1' when the measured temperature is outside limit range values defined by holding registers 11 and 12	0, 1	0 = Temperature range OK 1 = Temperature range too low/high
5	Temperature sensor state	unsigned integer	Flag that shows if the communication with temperature sensor is lost	0, 1	0 = OK 1 = Fault
6–9			Reserved, return 0		
10	Relative humidity level	unsigned integer	Actual relative humidity level	0–1.000	1.000 = 100 % rH
11	Relative humidity output value	unsigned integer	Output value according to relative humidity	0–1.000	1.000 = 100 %
12	Relative humidity alert flag	unsigned integer	Flag indicates that measured Relative humidity is outside set alert values. Set to '1' when the measured value is outside the Relative humidity alert values defined by holding registers 21 and 22	0, 1	0 = Relative humidity measurement OK 1 = Relative humidity measurement too low/high
13	Relative humidity range limit flag	unsigned integer	Flag indicates that measured Relative humidity is outside set range limit values. Set to '1' when the measured Relative humidity is outside limit range values defined by holding registers 19 and 20	0, 1	0 = Relative humidity range OK 1 = Relative humidity range too low/high
14	Humidity sensor state	unsigned integer	Flag that shows if the communication with humidity sensor is lost	0, 1	0 = OK 1 = Fault
15	Dew point level	signed integer	Calculated dew point	-700–700	200 = 20,0°C

**INPUT REGISTERS**

		Data type	Description	Raw data range	Values
16–20			Reserved, return 0		
21	CO <sub>2</sub> level	unsigned integer	Actual CO <sub>2</sub> level	0–5.000	2.000 = 2.000 ppm
22	CO <sub>2</sub> output value	unsigned integer	Output value 3 (CO <sub>2</sub> )	0–1.000	1.000 = 100 %
23	CO <sub>2</sub> alert 1 indication	unsigned integer	Indicates if CO <sub>2</sub> value is higher than Alert 1 Level defined by holding register 25	0, 1	0 = CO <sub>2</sub> measurement OK 1 = CO <sub>2</sub> measurement too high
24	CO <sub>2</sub> alert 2 indication	unsigned integer	Indicates if CO <sub>2</sub> value is higher than Alert 2 Level defined by holding register 26	0, 1	0 = CO <sub>2</sub> measurement OK 1 = CO <sub>2</sub> measurement too high
25	CO <sub>2</sub> sensor status	unsigned integer	Flag that shows if the communication with the CO <sub>2</sub> sensor is lost	0, 1	0 = OK 1 = Fault
26–40			Reserved, return 0		
41	Ambient light intensity	unsigned integer	Measured ambient light intensity	0–32.000	1.000 = 1.000 lux
42	Active / Standby	unsigned integer	Active or Standby indication according the Active / Standby light level defined by holding registers 35 and 36. If the measured light level is between the two levels the indication is 0 (Low light intensity)	0–2	0 = Low light intensity 1 = Active 2 = Standby
43	Ambient light sensor status	unsigned integer	Flag that shows if the communication with the ambient light sensor is lost	0, 1	0 = OK 1 = Fault
44–50			Reserved, return 0		

**Note:** The input registers can be read via the Modbus command: "Read input registers".

**HOLDING REGISTERS**

		Data type	Description	Raw data range	Values	Factory default values
1	Device slave address	unsigned integer	Modbus device address	1–247		1
2	Modbus baud rate	unsigned integer	Modbus communication baud rate	0–6	0 = 4.800    3 = 38.400    6 = 230.400 1 = 9.600    4 = 57.600 2 = 19.200    5 = 115.200	2
3	Modbus parity	unsigned integer	Parity check mode	0–2	0 = 8N1 1 = 8E1 2 = 8O1	1
4	Device type	unsigned integer	Device type. Read only	1.796	1.796 = RSMFM-3	
5	HW version	unsigned integer	Hardware version of the device. Read only	XXXX	0x0200 = HW version 2.0	
6	FW version	unsigned integer	Firmware version of the device. Read only	XXXX	0x0120 = FW version 1.2	
7–8			Reserved, return 0			
9	Modbus network resistor termination (NBT)	unsigned integer	Set device as end device of the line / or not by connecting NBT	0, 1	0 = NBT disconnected 1 = NBT connected	0
10	Modbus registers reset	unsigned integer	Resets Modbus Holding registers (above 10) to default values. When finished this register is automatically reset to '0'	0, 1	0 = Idle 1 = Reset Modbus Registers	0
11	Minimum temperature range	unsigned integer	Minimum value of temperature range, cannot be set higher than maximum temperature range minus 5°C	0–(Max - 50)	100 = 10,0°C	0
12	Maximum temperature range	unsigned integer	Maximum value of temperature range, cannot be set less than minimum temperature range plus 5°C	(Min + 50)–500	500 = 50,0°C	500

**HOLDING REGISTERS**

		Data type	Description	Raw data range	Values	Factory default values
13	Minimum temperature alert	unsigned integer	Minimum temperature alarm value	Min. temperature range—Max. temperature alarm	100 = 10,0°C	0
14	Maximum temperature alert	unsigned integer	Maximum temperature alarm value	Min. temperature alarm—Max. temperature range	500 = 50,0°C	500
15–18			Reserved, return 0			
19	Minimum relative humidity range	unsigned integer	The minimum relative humidity range value - it cannot be set higher than the maximum relative humidity range value minus 5%	0—(Max - 50)	200 = 20,0 % rH	50
20	Maximum relative humidity range	unsigned integer	The maximum relative humidity range value - it cannot be less than the minimum relative humidity range value plus 5%	(Min + 50)—1000	1.000 = 100 % rH	950
21	Minimum relative humidity alert	unsigned integer	Minimum relative humidity alarm value	Min. relative humidity range—Max. relative humidity alarm	200 = 20,0 % rH	300
22	Maximum relative humidity alert	unsigned integer	Maximum relative humidity alarm value	Min. relative humidity alarm—Max. relative humidity range	1.000 = 100 % rH	700
23	Minimum CO <sub>2</sub> range	unsigned integer	Minimum value of the CO <sub>2</sub> range. The value is used for calculating CO <sub>2</sub> output level	0—(Max - 100)	1.000 = 1.000 ppm	350
24	Maximum CO <sub>2</sub> range	unsigned integer	Maximum value of the CO <sub>2</sub> range. The value is used for calculating CO <sub>2</sub> output level	(Min + 100)—5.000	2.000 = 2.000 ppm	2.000
25	CO <sub>2</sub> Alert 1 level	unsigned integer	CO <sub>2</sub> value for 'Alert 1'. When the CO <sub>2</sub> value exceeds this value, Input register 23 will indicate '1'	0—(Alert 2 Level - 100)	400 = 400 ppm	900
26	CO <sub>2</sub> Alert 2 level	unsigned integer	CO <sub>2</sub> value for 'Alert 2'. When the CO <sub>2</sub> value exceeds this value, Input register 24 will indicate '1'	(Alert 1 Level + 100)—5.000	2.000 = 2.000 ppm	1.200
27–34			Reserved, return 0			
35	Active level	unsigned integer	The ambient light level above which 'Active' is indicated in input register 42	0—32.000	100 = 100 lux	100

**HOLDING REGISTERS**

		Data type	Description	Raw data range	Values	Factory default values
36	Standby level	unsigned integer	The ambient light level below which 'Standby' is indicated in input register 42	0–32.000	10 = 10 lux	10
37–39			Reserved, return 0			
40	CO <sub>2</sub> module self-calibration	unsigned integer	Enables or disables the CO <sub>2</sub> module self calibration technique. If enabled it is advisable that the CO <sub>2</sub> concentration drops to outside level (400 ppm) in a 7 day period.	0, 1	0 = Disabled 1 = Enabled	1
41–78			Reserved, return 0			
79	LED indication	unsigned integer	Select sensor to be related to LED indication	1–3	1 = Temperature 2 = rH 3 = CO <sub>2</sub>	3
80	LED brightness	unsigned integer	Set LED brightness	0–10	0 = OFF 5 = 50 %	5

**Note:** The holding registers can be managed via the following Modbus commands: "Read Holding Registers", "Write Single Register" or "Write Multiple Registers".

The free Sentera configuration and monitoring software 3SModbus can be downloaded via: <https://www.sentera.eu/eu/3SMCenter>