

Consult the fan manufacturer for the correct wiring. First connect the products, then download the firmware for this solution ID via SenteraWeb. The firmware will be automatically downloaded in the connected device(s).

Sentera products		External products	Parameters settings			
Article codes ECH-8-DM SEPS8-24-40 SIG-M-2 FLTSN-P500-040	Description Ambient temperature is measured. The higher the difference between the measured temperature value and the temperature setpoint, the higher the EC fan speed. The unregulated output controls a water valve or an electric heating element. This controller requires a separate LAN gateway to download the required firmware.	EC fan with 0-10 Volt control input Hot water valve (solenoid 230 VAC)	Article codes	Parameters	Values	Descriptions
This document is to be treated as an Consult our disclaimer on https://ww	n example or guideline only. Sentera bears no responsibility for any misprints, misinterpret rw.sentera.eu/	tations or mistakes in this document.				Release date: 26/09/2022



Solution ID:TA-W-000001