## ODTHM TEMPERATURE AND HUMIDITY OUTDOOR TRANSMITTER

## Modbus register map







## **MODBUS REGISTER MAP**

INPU	NPUT REGISTERS						
		Data type	Description	Raw data range	Values		
	Temperature reading	signed integer	Actual temperature level	-300—700	500 = 50,0°C		
!	Temperature output value	unsigned integer	Output value according to temperature	0—1.000	0 = 0 % 1.000 = 100 %		
	Temperature alert flag	unsigned integer	Flag indicates that measured Temperature is outside set alert values. Set to '1' when the measured value is outside the Temperature alert values defined by holding registers 13 and 14	0—1	0 = Temperature measurement OK 1 = Temperature measurement too low/high		
	Temperature range limit flag	unsigned integer	Flag indicates that measured temperature is outside set range limit values. Set to '1' when the measured temperature is outside limit range values defined by holding registers 11 and 12	0-1	0 = Temperature range OK 1 = Temperature range too low/high		
i	Temperature sensor state	unsigned integer	Flag that shows if the communication with temperature sensor is lost	0—1	0 = OK 1 = Fault		
-9			Reserved, return 0				
0	Relative humidity level	unsigned integer	Actual relative humidity level	0—1.000	1.000 = 100 % rH		
1	Relative humidity output value	unsigned integer	Output value according to relative humidity	0—1.000	0 = 0 % 1.000 = 100 %		
2	Relative humidity alert flag	unsigned integer	Flag indicates that measured Relative humidity is outside set alert values. Set to '1' when the measured value is outside the Relative humidity alert values defined by holding registers 21 and 22	0-1	0 = Relative humidity measurement OK 1 = Relative humidity measurement too low/hig		
3	Relative humidity range limit flag	unsigned integer	Flag indicates that measured Relative humidity is outside set range limit values. Set to '1' when the measured Relative humidity is outside limit range values defined by holding registers 19 and 20	0-1	0 = Relative humidity range OK 1 = Relative humidity range too low/high		
4	Humidity sensor state	unsigned integer	Flag that shows if the communication with humidity sensor is lost	0-1	0 = OK 1 = Fault		
5	Dew point level	signed integer	Calculated dew point	-700—700	200 = 20,0°C		





INPUT	INPUT REGISTERS						
		Data type	Description	Raw data range	Values		
16—40			Reserved, return 0				
41	Ambient light intensity	unsigned integer	Measured ambient light intensity	0—32.000	1.000 = 1.000 lux		
42	Active / Standby	unsigned integer	Active or Standby indication according the Active / Standby light level defined by holding registers 35 and 36. If the measured light level is between the two levels the indication is 0 (Low light intensity)	0-2	0 = Low light intensity 1 = Active 2 = Standby		
43	Ambient light sensor state	unsigned integer	Flag that shows if the communication with the ambient light sensor is lost	0-1	0 = OK 1 = Fault		
44—50			Reserved, return 0				
Note: The input registers can be read via the Modbus command: "Read input registers".							

\_\_\_\_





HOL	HOLDING REGISTERS						
		Data type	Description	Raw data range	Values		Factory default values
1	Device slave address	unsigned integer	Modbus device address	1—247			1
2	Modbus baud rate	unsigned integer	Modbus communication baud rate	0-6	0 = 4.800 1 = 9.600 2 = 19.200	3 = 38.400 6 = 230.400 4 = 57.600 5 = 115.200	2
3	Modbus parity	unsigned integer	Parity check mode	0—2	1 =	8N1 8E1 8O1	1
4	Device type	unsigned integer	Device type. Read only	1.663	1.663 =	ОДТНМ	
5	HW version	unsigned integer	Hardware version of the device. Read only	xxxx	0x0200 =	HW version 2.0	
6	FW version	unsigned integer	Firmware version of the device. Read only	xxxx	0x0200 =	FW version 2.0	
7—8			Reserved, return 0				
9	Modbus network resistor termination (NBT)	unsigned integer	Set device as end device of the line / or not by connecting NBT	0—1	0 = 1 =	NBT disconnected NBT connected	0
10	Modbus registers reset	unsigned integer	Resets Modbus Holding registers to default values. When finished this register is automatically reset to '0'	0—1		Idle Reset Modbus Registers	0
11	Minimum temperature range	signed integer	Minimum value of temperature range, cannot be set higher than maximum temperature range minus 5°C	-300—(Max - 50)	100 =	10,0°C	0
12	Maximum temperature range	signed integer	Maximum value of temperature range, cannot be set less than minimum temperature range plus 5°C	(Min + 50)—700	500 =	50,0°C	500
13	Minimum temperature alert	signed integer	Minimum temperature alarm value	Min. temperature range—Max. temperature alarm	500 =	50,0°C	0





		Data type	Description	Raw data range	Values	Factory default values
		Бата гуре	Description	Kaw data range	Values	Tactory default values
14	Maximum temperature alert	signed integer	Maximum temperature alarm value	Min. temperature alarm— Max. temperature range	500 = 50,0°C	500
15—18			Reserved, return 0			
19	Minimum relative humidity range	unsigned integer	Minimum value of relative humidity range, cannot be set higher than maximum relative humidity range minus 5%	0—(Max - 50)	200 = 20,0 % rH	(
20	Maximum relative humidity range	unsigned integer	Maximum value of relative humidity range, cannot be set less than minimum relative humidity range plus 5%	(Min + 50)—1000	850 = 85 % rH	1.000
21	Minimum relative humidity alert	unsigned integer	Minimum relative humidity alarm value	Min. relative humidity range—Max. relative humidity alarm	200 = 20,0 % rH	(
22	Maximum relative humidity alert	unsigned integer	Maximum relative humidity alarm value	Min. relative humidity alarm—Max. relative humidity range	850 = 85 % rH	1.000
23—34			Reserved, return 0			
35	Active light level	unsigned integer	The ambient light level above which 'Active' is indicated in input register 42	0-32.000	100 = 100 lux	100
36	Standby light level	unsigned integer	The ambient light level below which 'Standby' is indicated in input register 42	0-32.000	10 = 10 lux	10
37—78			Reserved, return 0			

Note: The holding registers can be managed via the following Modbus commands: "Read Holding Registers", "Write Single Register" or "Write Multiple Registers".

The free Sentera configuration and monitoring software 3SModbus can be downloaded via: https://www.sentera.eu/en/3SMCenter